



# Certificate of Compliance

**Certificate:** 2235006

**Master Contract:** 229226

**Project:** 2235006

**Date Issued:** 2009/12/24

**Issued to:** YASKAWA ELECTRIC AMERICA, INC

2121 NORMAN DRIVE SOUTH  
WAUKEGAN, IL 60085  
USA  
Attention: Dmitriy Leytman

*The products listed below are eligible to bear the CSA Mark shown*



*Patrick Quinty*

**Issued by:** Patrick Quinty

CSA B44.1 /  
ASME A17.5

## **PRODUCTS**

**CLASS 3211 06** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -  
Miscellaneous

**CLASS 2411 02** - ELEVATOR EQUIPMENT-Enclosed Elevator - and Escalator Electrical  
Equipment

Variable Speed Drives for AC Motors, Series CIMR,..., followed by A, E, H, L or T, followed by A through Z, followed by 2, 4 or 5 followed by A through Z, followed by XXXX, where XXXX is 0002 through 0675, followed by A or F, followed by XX, where XX is AA through ZZ; enclosed;

Ratings:

Input: 200 to 240Vac, 3.9A to 471A, 50/60Hz; Output: 0-240V, 3.5A to 415A

Input: 380 to 480Vac, 2.1A to 657A, 50/60Hz; Output: 0-480V, 2.1A to 675A

Input: 500 to 600Vac, 3.6A to 45A, 50/60Hz; Output: 0-600V, 2.7A to 32A

Note: Motor overload Protection. The control software provides solid state overload motor protection, Class 20.

## **APPLICABLE REQUIREMENTS**



**Certificate:** 2235006

**Master Contract:** 229226

**Project:** 2235006

**Date Issued:** 2009/12/24

- 
- |  |   |   |
|--|---|---|
| CAN/CSA C22.2 No.0.4-04                  | - | Bonding of Electrical Equipment                                   |
| CAN/CSA C22.2 No 14-05                   | - | Industrial Control Equipment                                      |
| CSA B44.1-04 / ASME A17.5-2004           | - | Elevator and Escalator Electrical Equipment                       |
| *ANSI/UL508C (3rd Edition)               | - | Power Conversion Equipment  |
| *ANSI/UL 746C (6th Edition)<br>Equipment | - | Standard for Polymeric Materials – Use in Electrical<br>Equipment |

\* Used as a guide